



Performance Evaluation of IEC 61850 safety-related communication architecture

Ahmed Altaher, Jean-Marc Thiriet, Stéphane Mocanu

► To cite this version:

Ahmed Altaher, Jean-Marc Thiriet, Stéphane Mocanu. Performance Evaluation of IEC 61850 safety-related communication architecture. Summer School on Cyber-Physical Systems - 2014 Edition, Université Joseph Fourier; PERSYVAL-Lab; NASA-JPL, Jul 2014, Grenoble, France. hal-01242259

HAL Id: hal-01242259

<https://hal.science/hal-01242259>

Submitted on 14 Dec 2015

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Performance Evaluation of IEC 61850 safety-related communication architecture

Ahmed ALTAHER¹, Jean-Marc THIRIET, Stéphane MOCANU
GIPSA-lab control systems dept. Grenoble (UMR 5216 CNRS-INPG-UJF)

Abstract

Recent improvements, in electrical power transmission and distribution, require considerations of existing regulations that enforce increasing of reliability and reducing of environment impact.

Smart grids become industrial solutions that follow standardized development. It is used to satisfy both the electrical energy supply from producers to consumers and the need for consumers' data transmission to electrical utility and providers. This technology is affected by international standardization in the field of power transmission and distribution.

Modern electrical substations, i.e. electrical transmission and distribution stations, are part of smart grids. These substations follow new technological trends [1].

The IEC 61850 standard consists of 10 parts to enforce interoperability between different manufactured devices, e.g. intelligent electronic device (IED), in the substation communication systems [2].

The standard uses high speed time-critical communication to exchange events and states between substation devices. This standard sets a latency constraint to achieve a response time of less than four milliseconds for critical event communications, especially in the protection and automation fields [3].

One of the objectives of the current research is to evaluate latency of Ethernet based GOOSE (General Object Oriented Substation Events), i.e. time-critical messages, transmission for both message priority and time delay.

In particular, to evaluate these parameters, especially when network redundancy is existed, a simulation model scenario is developed.

In this study modeling is done by employing Matlab Simulink and Stateflow libraries. A model uses state machine charts is therefore used to build and evaluate GOOSE real time communications. The main components of the model are Ethernet network, publisher and subscriber IEDs. This model and its components are simulated to provide frame delivery delays to measure the network latency.

The first model is a simple station bus architecture that gave interesting results. Its output will be verified to validate GOOSE communication paradigm in respect of the standard time constraint.

The main aim of this research is to evaluate safety-related functions and their reaction, i.e. protective relay response, hence that current work will require further expansion to simulate safety-related functions and network redundancy within an IEC 61850 substation network.

Keywords: Smart Grid, Time-Critical, Ethernet, Safety.

[1] ALSTOM, Network Protection and Automation Guide, edition may 2011

[2] IEC 61850 standard and its parts

[3] S. Choi, C. Kim, S. Choi, I. Kim and T. Jeong, *Communication Interconnection Network Architecture and Logical Devices Application, international journal of software engineering and its applications, Vol. 6, No. 3, July, 2012*